

One Information Way, Suite 225

Little Rock, AR 72202

501-945-4506 ■ 800-365-4506 ■ Fax: 501-945-7718

[www.tarcoroofing.com](http://www.tarcoroofing.com)



## TECHNICAL BULLETIN LB-07-08-R1

### Fast90™ and PS200<sup>HT</sup> - Application Update

This bulletin revises Tarco's specification with respect to back nailing LeakBarrier® Fast90 and LeakBarrier® PS200<sup>HT</sup> self-adhering underlayments. This technical bulletin is effective April 12, 2010.

Tarco requires the back nailing of all its underlayments. The back nailing requirements include using minimum 11 gauge fasteners applied with a minimum 1" disk. When installing Fast90 and PS200<sup>HT</sup> at roof slopes equal to or greater than 2:12, the fasteners and disks shall be fastened at a minimum rate of 9" o.c. The fastening of Tarco underlayments shall be in accordance with Tarco's published installation instructions or applicable building codes. Please refer to applicable building codes prior to installation.

If Fast90 and PS200<sup>HT</sup> published installation instructions and the above guidelines are not strictly followed, Tarco will not be responsible for the product performance.

If you have any questions or require additional information, please contact your local Tarco Sales Representative or email Tarco Technical Services at [technicalservice@tarcoroofing.com](mailto:technicalservice@tarcoroofing.com)